

Achievements during the year 2020-21

Sr No.	Discription	Unit	Total
A	<u>Progress of OHE work:</u>		
1	Foot patrolling	TKM	10399.94
2	Checking of Cross- overs	No.	704
3	Checking of Turn-outs	No.	780
4	Checking of overlaps	No.	653
5	Live Line T W inspection	TKM	3027
6	AOH of Mast Cantilevers/other OHE Asset	TKM	963.19
7	Checking of NS -PTFE/Section Insulator type	No.	210
8	AOH /POH of ATD	No.	325
9	AOH of SI	No.	372
10	Erection of TTB	No.	73
11	Dismantling of upright / Boom	No.	203
12	New overlap formation	No.	39
13	Replacement of Cross feeder	No.	23
14	Checking of Isolator	No.	391
15	Replacement of Contact wire	Km	14.61
16	Replacement of Catenary wire	Km	34.36
17	Replacement of steel structure	MT	49.02
18	AOH of OHE	Km	549.05
19	POH of OHE	Km	244.64
20	CWWR of OHE	Km	527.03
21	TW checking	Km	517.73
22	Total trees cut	No.	973
23	Total trees trimmed	No.	23457
24	Replacement of Flashed/Broken/chipped, 9T, BT, ST insulators	No.	426
25	Checking of LA	No.	343
26	Checking of Disconnecter Switch	No.	110
27	Checking of Neutral section	No.	176
28	Checking of ATD	No.	2105
29	Checking of Bonds	No.	78356
30	Checking of Cantilever	No.	15719

Sr No.	Discription	Unit	Total
B	<u>Progress of PSI work:</u>		
1	AOH of 25 KV CB	No.	308
2	AOH of 25KV CT	No.	271
3	AOH of 25KV PT	No.	269
4	AOH of 42 KV LA	No.	297.583
5	Meggering and checking of earth resistance	No.	1935
6	Control & Relay panel	No.	155
7	Maintenance of AT (TSS)	No.	144
8	Maintenance of AT (CLS)	No.	231
9	AOH of DPI	No.	251
10	Gantry Maintenance carried out at SP SSP & TSS	No.	111
11	Checking of LA-THRC and meggering	No.	624
12	Checking of LA Disconnecter	No.	717
13	Thermographic checking of PG, Jumpers, connections etc	No.	17800